

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 105

Dated: 11/04/25

It is certified that an inspection team headed by Rural water Supply & Sanitation

(Name of Officers with designation) from Kamal Lochan Nayak, JE, RW S&S

(Name of Department/ Office) inspected the (R.W.S. & S.T. Xavier's Public School)

(Name & Address of the school) on 9/4/2025 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt

The above is valid for a period of One Year from date of inspection

Signature with Seal: (Kamal Lochan Nayak)

Name

Junior Engineer

Designation:

R.W.S&S Chatrapur

Assistant Engineer of

the Govt. Public Health Department (PHED)/

Authorised officer of the Local Body

Name & Address of the Office / Department

JE, RW S&S, Section

Chatrapur, under Berhampur  
Division.

To

The Chairman

ST. Xavier's Public School; Chatrapur.

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

No. 110<sup>(Lab)</sup> /dt 29.03.2025  
To

The Chairman,  
St. Xavier's Public School,  
Hemalata Nagar, Near fire station,  
Chtrapur-761020.

Sub : Water Quality Test Report of St. Xavier's Public School.


Sir,

With reference to the water samples submitted by you at District Water Testing Laboratory, Berhampur, the same has been tested for the following Parameters.

Sl.No.	Parameter	Units	Permissable Limit	Testing Value
				Tap water
1	Alkalinity	Mg/ltr	600	32.0
2	Chloride	Mg/ltr	1000	28.0
3	Fluoride	Mg/ltr	1.5	0.08
4	Total Hardness	Mg/ltr	600	36.0
5	Iron	Mg/ltr	1.0	0.210
6	pH	--	6.5-8.5	6.69
7	Elec.Conductivity	( $\mu$ mho/cm)	--	56.49
8	TDS	Mg/ltr	2000	33.894
9	Turbidity	NTU	5	1.66

Water is safe for Drinking because testing values are under permissible limit.

Yours faithfully,

  
CEO-cum-Executive Engineer(RWSS)  
Chief Executive Officer  
-cum-  
Executive Engineer  
District Water Testing Laboratory  
RWSS Division, Berhampur